



LAWN IRRIGATION ROUGH PLUMBING INSPECTION AFFIDAVIT

Permit #: _____

Site Address: _____

Contractor / Applicant Name: _____

License #: _____

The undersigned authority being duly sworn, deposes and says of his or her personal knowledge, attest to the following:

- Schedule 40 PVC is required for all static pressurized water lines. PVC purple pipe is mandatory for all non-potable water sources including irrigation systems.
- Burial depth shall be 12" for all static pressure lines and 6" for all lateral lines.
- PVC must have purple primer that conforms to ASTM F656 and shall be applied to PVC solvent-cement joints. Solvent cement for Purple PVC plastic pipe conforming to ASTM D2564 shall be applied to all joint surfaces.
- All water piping is sized to assure that the maximum water velocity does not exceed 5 fps.
- All low voltage wire which is directly buried, is labeled for Direct Burial.
- All photos submitted must include a date/time stamp.
- The photographic evidence shall be comprehensive in the display of the installation and/or construction and job location identifiers.

This affidavit and the necessary photos must be uploaded to the portal prior to scheduling the Rough Plumbing and Plumbing Final inspection (The rough plumbing and plumbing final shall be scheduled for the same date). In addition, a copy of the affidavit and accompanying photographs shall be provided to the inspector onsite.

If the photographs are found to be insufficient by the building official to demonstrate compliance with this code, statute, Land Development Code and/or the permitted documents, or clearly display location identifiers, or are missing information, the inspector shall require the contractor to obtain the services of a Registered Florida Professional Engineer to inspect and certify the installation and/or construction.

Under penalties of perjury, I declare that I have read the foregoing LAWN IRRIGATION ROUGH PLUMBING INSPECTION AFFIDAVIT and that the facts stated in it are true. I hereby affirm, that all the foregoing information is true and accurate and that the irrigation system at the above referenced permit/address was designed and installed to comply with F.S. Title. XXVIII, Ch. 373, § 228, the City of Cape Coral Code of Ordinance 46-23 and reference the Florida Building Code, Plumbing Volume, Appendix F. 8th Edition (2023).

Contractor / Owner/Builder Signature

Date

A person who knowingly makes a false declaration under subsection (2) is guilty of the crime of perjury by false written declaration, a felony of the third degree, punishable as provided in s. 775.082, s. 775.083, or s. 775.084.