



NAIL SALON EXHAUST SYSTEM

(COMMERCIAL)

FLORIDA MECHANICAL CODE 403.1.1 AND 501
May be applied for by Mechanical Contractors Only

- Miscellaneous Application
- Four Copies of plans to include the following
 - Floor plan of the entire space
 - Locations of stations (identify & label floor plan)
 - Size (cfm) and location of in line exhaust fan
 - Size, location, route and support of exhaust ducts
 - Location of outside termination (through roof or sidewalls)

Processing: OFFICE USE ONLY

- Type: Mechanical/HVAC
- Subtype: Commercial

Description:

- Salon Name and Unit number on description line. In description note pad call out if it is a new system or modification to an existing.

Route To:

- Fire
- Mechanical

Inspections:

- | | |
|--------------------------------|----|
| • Notice of Commencement (NOC) | 10 |
| • HVAC Rough 012 | 20 |
| • HVAC Final 042 | 30 |

Fee's:

- | | |
|-------------------------|----------|
| • Mechanical Permit Dep | \$ 22.39 |
| • Mechanical Permit | 126.86 |
| • Surcharge | YES |

Expiration:

- Two Months

NOTES:

No recirculating systems allowed - Hazardous exhaust must terminate outside the building or individual unit.

Separate electrical permit required

50 cfm minimum per nail station

Inlet must be within 12 inches of source height (manicure table/pedicure station).

Required clearance per FMC 501.3.1

Back draft damper required

Fan must be accessible